

**Société CLIMATECH INTERNATIONAL**

236/238 avenue GEVAERT  
B - 1332 GENVAL

O/Ref : E-LAB - 158/16 - RCH/BM

Maizières-lès-Metz, July 12<sup>th</sup> 2016

Test certificate

Attention: Mister François-Xavier GOHY

Dear Mister GOHY,

Following the tests (CTICM n° 05-E-229 and 05-G-241) described in the classification report of CTICM n° 05-B-284 concerning the fans tested with the flexible duct connectors of CLIMATECH INTERNATIONAL S.A., of trademark 011203 PU/POLYURETHANE, fixed by metal belts and clamps to a piping. It appears that these flexible duct connectors have ensured their role for 120 minutes while being subjected to a heated gas passage of 400°C under a hot depression of 650 Pa (test from CTICM n° 05-G-241) and 85 Pa (test from CTICM n° 05-E-229).

We remain at your disposal.

Yours sincerely.



Roman CHIVA  
Testing Development Deputy Director



POUR COPIE CONFORME



**Benoît le MAIRE**  
Notaire