



Declaration of conformity

Herewith

ATCO EUROPE

declares that the flexible duct named:

SEMIFLEX

Classified : A1 (Non combustable)

has been tested and classified according :

EN 13501-1:2002

*"Fire classification of construction products and building elements –
Part 1: Classification using test data from reaction to fire tests"
(TNO report nr.2005-CVB-R0107)*

To check the validity of this declaration please contact:

ATCO Europe