



# Declaration of conformity

Herewith

**ATCO EUROPE**

declares that the flexible duct named:

---

**ISOSLEEVE 50**

(based on ISOSLEEVE25)  
**Considered Classified : B s1 d0**

---

*has been tested and classified according :*

**EN 13501-1:2002**

*“Fire classification of construction products and building elements –  
Part 1: Classification using test data from reaction to fire tests”  
(TNO report nr.2005-CVB-R0108)*

**Test Methods:**

**NEN-EN 13823:2003**

*“Reaction to fire tests for building products –  
Building products excluding floorings exposed to  
the thermal attack by a single burning item”  
(TNO report nr.2005-CVB-R0076)*

**NEN-EN-ISO 11925-2:2002**

*“Reaction to fire tests – Ignitability of building products  
subjected to direct impingement of flame –  
Part 2: Single-flame source test”  
(TNO report nr.2005-CVB-R0077)*

To check the validity of this declaration please contact:

**ATCO Europe**