



CZECH TECHNICAL UNIVERSITY IN PRAGUE  
FACULTY OF CIVIL ENGINEERING –  
TESTING LABORATORY  
testing laboratory No. 1048 accredited by  
CIA under ČSN EN ISO/IEC 17025:2018  
Thákurova 7, Praha 6, 166 29



**L 1048**

EXPERT LABORATORY OL 181  
Třinecká 1024,273 43. Bustěhrad, Czech Republic  
phone: 00420 224 355 429  
email: daniel.adamovsky@fsv.cvut.cz

No. of copies: 3  
Copy No: 1  
No. of pages: 9  
Page No.: 1  
No. of annexes: 1  
No. of annexes pages: 1

**Order No.: A24040**

## **TEST REPORT** number: 181158/2024

**on testing: Air handling unit (trade name CPX8) from manufacturer MANDÍK, a.s. according to standard EN 308.**

**Client's name and address:**

**MANDÍK, a.s., Dobříšská 550, 267 24 Hostomice  
Czech Republic**

**Date of test report issue: 24. 4. 2024**



**Approved by:**

doc. Ing. Jiří Litoš, Ph.D., OL 181 Technical Manager

signature

*This test report can only be reproduced in its entirety, in part only with a written consent of the testing laboratory. The results of tests refer exclusively to the subject of the test (test specimen).*

**Subject of the test:** Heat exchangers for heat recovery in ventilation systems

**Testing procedure:** Serial No. 181/14 - Measurement of performance parameters

**Test regulation:** EN 308

**Test specimen were manufactured by:** Client – results refer to the specimen as it was taken over

**Date of taking over test specimen:** 17.4.2024

**Specimen taken over by:** Martin Kny

**Manufacturing site of test specimen:** Dobříšská 550, Hostomice, Czech Republic

**Date of manufacturing test specimen:** 2024

**Test specimen manufactured by:** MANDÍK, a.s

**Marking of test specimen:** CPX8

**Test execution date:** 18 - 19. 4. 2024

**Test execution place:** Czech Technical University In Prague, University Center For Energy Efficient Buildings, Trinecká 1024, 273 43, Bustěhrad, Czech Republic

**Potential data on deviations from the test regulation:** According to the client's request, only the temperature ratio test for winter conditions (Winter W1) was carried out at a nominal air flow rate of 800 m<sup>3</sup>/hr.

**Data on uncertainties of quantitative results:** The expanded uncertainties of measurement U are the product of standard measurement uncertainties and the expansion coefficient k=2, which provides a confidence interval of ca 95 %

**Name of the person who performed the test (measurement):** Martin Kny

**Name of the person who compiled the test report:** Daniel Adamovský

**Test results:** are shown on page 5.

### 1) Test Specimen Parameters - Air handling unit

Tab. 1 Parameters of the air handling unit

Dimensions	1910 x 485 x 987 mm (L x V x H)*
Weight	# 230 kg#
AHU class according to standard	HRC1a
Supply fan position	downstream of the heat exchanger
Exhaust fan position	downstream of the heat exchanger

\* without protruding parts (anchoring handles, throats)

Detailed photodocumentation of the air handling unit is given in chapter 5

### 2) Test boundary conditions according to ČSN EN 308

Tab. 2 Boundary condition

Test TYPE B
Precision Class P2
Test condition Winter W1 (without condensation)

According to the client's requirements, only the thermal efficiency  $\eta_{t,gr0}$  was measured at a nominal flow rate of 800 m<sup>3</sup>/hr.

Tab. 3 Boundary condition for test condition Winter W1

Inlet dry bulb temperature exhaust air	25	°C
Inlet wet bulb exhaust air	<14	°C
Inlet dry bulb temperature fresh air	5	°C
Inlet wet bulb temperature fresh air	no requirement	°C

### 3) Measuring equipment

Tab. 4 Measuring equipment

Sensor/Manufacturer	Serial number	Calibration validity	Calibration range	Number of cal. points
Temp. and humidity Rotronic HC2-S+E2-XX	20043035	15.12.2025	-20 to 60 °C	3
		15.12.2025	10 to 85 % rh	3
Temp. and humidity Rotronic HC2-S+E2-XX	20043036	15.12.2025	-20 to 60 °C	3
		15.12.2025	10 to 85 % rh	3
Temp. and humidity Rotronic HC2-S+E2-XX	20043070	15.12.2025	-20 to 60 °C	3
		15.12.2025	10 to 85 % rh	3
Temp. and humidity Rotronic HC2-S+E2-XX	20043071	15.12.2025	-20 to 60 °C	3
		15.12.2025	10 to 85 % rh	3
Temp. and humidity Rotronic HC2-S+E2-XX	20043072	15.12.2025	-20 to 60 °C	3
		15.12.2025	10 to 85 % rh	3

Anemometer SVH-I4SVH	4F151108492	27.01.2026	0.5 to 9.5 m/s	4
Anemometer SVH-I4SVH	4F151108493	27.01.2026	0.5 to 9.5 m/s	4
Anemometer SVH-I4SVH	4F151108494	27.01.2026	0.5 to 9.5 m/s	4
Anemometer SVH-I4SVH	4F151108496	27.01.2026	0.5 to 9.5 m/s	4
Air temperature Sensit TG8-40 10 m	30646/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30647/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30117/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30128/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30650/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30130/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30652/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30653/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30654/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30655/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30656/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30657/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30708/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30714/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30679/1015	09.12.2025	-20 to 60 °C	3
Air temperature Sensit TG8-40 10 m	30680/1015	09.12.2025	-20 to 60 °C	3
Differential pressure SVD 311	2524/15	05.01.2026	0 to 500 Pa	6
Differential pressure SVD 311	2525/15	06.01.2026	0 to 500 Pa	6
Differential pressure Beck 984Q	Z2-11106588/ 000	08.01.2026	0 to 500 Pa	12
Differential pressure Beck 984A	122816	08.01.2026	0 to 2500 Pa	10
Atmospheric pressure HUBA Control	155782	15.12.2025	0.8 to 1 bar	4
Wattmeter HIOKI PW 3335	160128191	11.12.2025	0 to 700 W	4
Tape measure	160128197	11.12.2025	0 to 5m	5

*All electronic equipment was calibrated as a complete chain together with the Datataker DT85 data loggers (sn. 106149 or sn. 106146).*

#### 4) Measurement results

Tab. 5 Measurement results

Electrical power		$P_E$	425 ± 1.4	W
Fan speed adjustment (fresh air/exhaust air)		-	F78/E77	%
Atmospheric air pressure		$P_{atm}$	97.0 ± 0.3	kPa
Fresh air	Inlet dry bulb temperature	$\theta_{21}$	5.03 ± 0.3	°C
	Inlet relative air humidity	$rh_{21}$	75.31 ± 2.4	%
	Outlet dry bulb temperature	$\theta_{22}$	20.63 ± 0.3	°C
	Outlet relative air humidity	$rh_{22}$	24.84 ± 2.3	%
	Inlet total pressure	$p_{21}$	28 ± 0.8	Pa
	Onlet total pressure	$p_{22}$	230 ± 1.2	Pa
	Available total pressure	$\Delta p_{s1,ext}$	202 ± 1.2	Pa
	Volumetric air flow	$q_{v22}$	800 ± 4.2	m <sup>3</sup> /hr
Mass flow rate		$q_{m22}$	0.254 ± 0.013	kg/s
Exhaust air	Inlet dry bulb temperature	$\theta_{11}$	24.96 ± 0.3	°C
	Inlet relative air humidity	$rh_{11}$	19.45 ± 2.5	%
	Outlet dry bulb temperature	$\theta_{12}$	9.41 ± 0.3	°C
	Outlet relative air humidity	$rh_{12}$	48.70 ± 2.4	%
	Inlet total pressure	$p_{11}$	4 ± 0.8	Pa
	Onlet total pressure	$p_{12}$	205 ± 1.3	Pa
	Available total pressure	$\Delta p_{s2,ext}$	201 ± 1.4	Pa
	Volumetric air flow	$q_{v12}$	809.3 ± 4.3	m <sup>3</sup> /hr
Mass flow rate		$q_{m12}$	0.254 ± 0.014	kg/s
Temperature gross efficiency		$\eta_{t,gro}$	0.783 ± 0.025	-

The expanded uncertainties of measurement  $U$  are the product of standard measurement uncertainties and the expansion coefficient  $k=2$ , which provides a confidence interval of ca 95 %

### 5) Photo documentation




Fig. 1 Tested air handling unit



Fig. 2 Internal layout of the air handling unit




Fig. 3 Air handling unit during measurement




Fig. 4 Electrical switchboard (after removing the cover)



MANDÍK		
MANDÍK s.r.o.	261 24 Kabinice	Hermanova 500 Česká republika
Prod. N.: 0702-8974	R4821001	CPXB
Prod. year: 2024	Tot. weight: 230 kg	
CEN 40227 EN 30050 EN 12058		
<b>SUPPLY</b>		
Nominal air flow: 800 m <sup>3</sup> /h		
<b>FILTER CHAMBER</b>		
(F7) ePM10 85% - pleat filter 96 mm		
initial pressure loss: 48 Pa Max. allowed final pressure loss: 300 Pa		
1 x 370x380 mm		
recommended pressure loss for replacement: 200 Pa		
<b>PLATE HEAT EXCHANGER CHAMBER</b>		
plate heat exchanger pressure drop-supply: 156 Pa		
bypass damper: 150 N		
<b>FAN CHAMBER</b>		
type: RH25I-6ID-8D-CR		
Pex=200 Pa, Ptot=463 Pa, η-factor=67		
nom. max. input: 2487/3170 rpm, 0.5 kW, 1x230 V, 2.5 A, f=50/60 Hz		
differential pressure drop by nominal airflow: 143 Pa		
<b>DAMPERS</b>		
ODA 0.4 Nm		

Fig. 5 Air handling unit specifications

MANDÍK		
MANDÍK s.r.o.	261 24 Kabinice	Hermanova 500 Česká republika
Prod. N.: 0702-8974	R4821001	CPXB
Prod. year: 2024	Tot. weight: 230 kg	
CEN 40227 EN 30050 EN 12058		
<b>EXHAUST</b>		
Nominal air flow: 800 m <sup>3</sup> /h		
<b>FILTER CHAMBER</b>		
(M5) ePM10 50% - pleat filter 96 mm		
initial pressure loss: 28 Pa Max. allowed final pressure loss: 300 Pa		
1 x 370x380 mm		
recommended pressure loss for replacement: 200 Pa		
<b>PLATE HEAT EXCHANGER CHAMBER</b>		
plate heat exchanger pressure drop-exhaust: 150 Pa		
<b>FAN CHAMBER</b>		
type: RH25I-6ID-8D-CR		
Pex=200 Pa, Ptot=472 Pa, η-factor=67		
nom. max. input: 2487/3170 rpm, 0.5 kW, 1x230 V, 2.5 A, f=50/60 Hz		
differential pressure drop by nominal airflow: 143 Pa		
<b>DAMPERS</b>		
EHA 0.4 Nm		

Fig. 6 Air handling unit specifications




Fig. 7 Exhaust fan




Fig. 8 Supply fan






Fig. 9 Filter – Fresh air




Fig. 10 Filter – Exhaust air




Fig. 11 Exchanger bypass flap (fresh air side)



Fig. 12 Exchanger, bypass, condensate drain and fan

*# the data marked as such was supplied by the customer, OL181 is not responsible for it.*

----- end of test report -----

## Annex 1

According to the client's requirements, the results of the measurements according to EN 308 were also expressed according to the test code in paragraph 5.2.1 of the document:

"Doc\_4.4\_S.a\_FR\_Ventilateurs\_et\_Groupes\_de\_ventilation\_v2.0\_20211025"

### Calculation of the temperature ratio

The test volume flow rate  $q_{v,test}$  is defined as the lower of the following two volume flow rates the exhaust air volume flow rate ( $q_{v11}$ ) and the supply air volume flow rate ( $q_{v22}$ ) during the test. The thermal efficiency of the heat recovery unit is given by:

$$\eta_{test} = \frac{(\eta_{t,sup} + \eta_{t,eha})}{2}$$

The temperature ratios of the supply air side ( $\eta_{t,sup}$ ) and the extract air side ( $\eta_{t,eha}$ ) are calculated using the temperatures measured during the test and are conventionally corrected to take account of the heat from electrical energy consumed:

$$\eta_{t,sup} = \frac{t_{22} - \Delta t_{22} - t_{21} - \Delta t_{21}}{t_{11} + \Delta t_{11} - t_{21} - \Delta t_{21}} \quad \text{et} \quad \eta_{t,eha} = \frac{t_{11} + \Delta t_{11} - t_{12} + \Delta t_{12}}{t_{11} + \Delta t_{11} - t_{21} - \Delta t_{21}}$$

The temperature differences ( $\Delta t_{xx}$ ) corresponding to the position of the fans.

Tab. 6 Measurement results

Fresh air fan position		downstream of the heat exchanger		
Exhaust air fan position		downstream of the heat exchanger		
Fan speed adjustment (fresh air/exhaust air)		-	F 78/E 77	%
Electrical power		$P_{elec.ahu.test}$	425	W
Specific Fan Power (SFP)		$P_{SFP}$	0.956	kW/m <sup>3</sup> /s
Atmospheric air pressure		$P_{atm}$	97.0	kPa
<b>Fresh air</b>	Inlet dry bulb temperature	$t_{21}$	5.03	°C
	Outlet dry bulb temperature	$t_{22}$	21.46	°C
	Available total pressure	-	202	Pa
	Volumetric air flow	$q_{v22}$	800.0	m <sup>3</sup> /hr
<b>Exhaust air</b>	Inlet dry bulb temperature	$t_{11}$	24.96	°C
	Inlet dew point temperature	-	0.1	°C
	Inlet wet air temperature	-	12.1	°C
	Outlet dry bulb temperature	$t_{12}$	10.24	°C
	Available total pressure	-	201	Pa
	Volumetric air flow	$q_{v11}$	809.3	m <sup>3</sup> /hr
$\Delta t_{11}$		$\Delta t_{11}$	0.00	K
$\Delta t_{12}$		$\Delta t_{12}$	0.83	K
$\Delta t_{21}$		$\Delta t_{21}$	0.00	K
$\Delta t_{22}$		$\Delta t_{22}$	0.83	K
$\eta_{t,sup}$		$\eta_{t,sup}$	78.3	%
$\eta_{t,eha}$		$\eta_{t,eha}$	78.0	%
<b>Test air flow</b>		<b><math>q_{v,test}</math></b>	<b>800.0</b>	<b>m<sup>3</sup>/hr</b>
<b>Final thermal efficiency</b>		<b><math>\eta_{t,epb}</math></b>	<b>78</b>	<b>%</b>