



# Climate Systems

Brink Climate Systems B.V.  
Postbus 11 7950 AA Staphorst  
R.D. Bügelstraat 3 7951 DA Staphorst  
T (0522) 46 99 44  
F (0522) 46 94 00  
E info@brinkclimatesystems.nl  
I www.brinkclimatesystems.nl  
Rabobank rek.nr. 35.65.56.808

## Declaration of Conformity according Standard EN 308 / EN 13141-7:2004

On behalf of Brink Climate Systems B.V., located in Staphorst, the energetic efficiency was determined by TNO Bouw, located in Apeldoorn. The determination was executed according the standard EN 308, heat exchangers -Test procedures for establishing performance of air to air and flue gases heat recovery devices and EN 13141-7, Ventilation for buildings - Performance testing of components/products for residential ventilation.

Manufacturer : Brink Climate Systems B.V.  
Type : Renovent Excellent 400

Air flow [m <sup>3</sup> /h]	$\eta_{WTW}$ [%]	$P_{el}$ [W]	I [A]	cos $\phi$
50	93,3	9,4	0,12	0,34
225	85,2	48,7	0,42	0,51
400	81,4	153,6	1,22	0,55
Average	86,6			

Date : 17 februari 2011

Brink Climate Systems B.V.

Klaas ter Horst  
Manager R&D

Measurement-results are specified in report BRR 060-APD-2011-00068, dated July 2011

